



**TOWN OF BABYLON
DEPARTMENT OF PLANNING & DEVELOPMENT**

200 East Sunrise Highway
Lindenhurst, NY 11757-2598
Phone (631) 957-3102 Fax (631) 957-4254

SMOKE DETECTOR REQUIREMENTS

For Rental Permits:

- Battery-operated smoke detectors are required in each bedroom.
- Battery-operated smoke detectors are required for any hallway leading to a bedroom.
- One battery-operated smoke detector is required for each level of the dwelling including the basement/cellar and attic.

For Accessory Apartment Permits:

- Battery-operated smoke detectors are required in each bedroom.
- Electrically hardwired smoke detectors are required for any hallway leading to a bedroom.
- One battery-operated smoke detector is required for each level of the dwelling including the basement/cellar and attic.

FOR ALL NEW CONSTRUCTION:

- All smoke detectors must be electrically hardwired with battery backup. No battery-operated smoke detectors are permitted.